



Approved Tubing List

The tubing types/brands listed below are approved for use with Warmboard panels:

Barrier PEX Tubing 1/2" I.D.:

- Kitec (Pex Aluminum Pex)
- Weil-McLain (Pex Aluminum Pex)
- Wirsbo MultiCor - (Pex Aluminum Pex)
- Vanguard - (Pex Aluminum Pex)
- Mr. Pex - (Pex Aluminum Pex)
- Infloor Heating Systems - (Pex Aluminum Pex)

Non-Barrier PEX Tubing 1/2" I.D.:

- Embassy
- Heatlink
- Infloor
- Roth
- Rehau
- Stadler
- Thaw-Pak
- Vanguard
- Qest/Zurn
- Watts Radiant
- Wirsbo AQUAPEX
- CPI
- Radiant Tech

When the designer/installer is using non-barrier tubing; it is mandatory to eliminate all corrodible Ferrous components. The use of any cast iron components are not approved for use with any non-barrier tubing system - check boiler type, pumps, and expansion tank. Follow all Radiant Panel Association (RPA) Guidelines.

Other tubing brands may be acceptable - please check with Warmboard Technical Services.

A note about PEX Aluminum PEX:

The use of PEX Aluminum PEX can eliminate the need for silicon during installation in Warmboard. Please consult Warmboard Technical Services with any questions or see the installation instructions for more information.

For technical assistance call Warmboard toll-free 1-877-338-5493